



NEVILLE AGGREGATES CO. INC.

Construction Aggregates Supplier

3501 Neville Road, Pittsburgh PA 15225

P 412.771.4001

F 412.771.0207

January 1, 2023

PennDOT Ref. #: GRCWA14
Material Type: #67 Limestone

To Whom It May Concern:

This letter is to verify that Neville Aggregates Co. Inc., Neville Island, is an agent for Greer Limestone Company, Morgantown, WV. Greer Limestone Company produces the limestone material provided for your use in accordance with the requirements of PennDOT Publication 408, Section 703 for aggregates and ASTM C-33 for concrete aggregates.

Sincerely,

A handwritten signature in black ink that reads 'Caleb T. Bryan'.

Caleb T. Bryan

A handwritten signature in black ink that reads 'David T. Giehll'.

David T. Giehll

Quality Test Report

BMG Research & Development Center

3507 Neville Road, Pittsburgh PA 15225



Plant Neville Aggregates - Neville Island Terminal
Product #67 Limestone
Source Greer Limestone - GRCWVC14
Specification PennDOT 408 Section 703

Sample Information

Sample No	Average	Weather	-
Start Date	1/10/2022	Temp	0
Finish Date	12/27/2022	Split Sample	<input type="checkbox"/>
Sampled By	David Giehll	Resample	<input type="checkbox"/>
Tested By	David Giehll	Lot/Sublot	-
Type	Production Sample	Quantity	50 lbs
Method	Stockpile		

Gradation Results

Units	Moist Mass	Dry Mass	Moisture %		Wash ST	Wash End	Wash Loss %
lbs	22.75	22.48	1.22%		10.540	10.434	1.01%
Sieve	Mass Retained	Cum Mass Retained	Ind % Retained	% Retained	% Passing	Target	Specification %
1 1/2"	0.00	0.00	0.0	0.0	100.0	100	100
1"	0.00	0.00	0.0	0.0	100.0	100	100
3/4"	0.90	0.90	4.0	4.0	96.0	95	90
1/2"	6.07	6.97	27.0	31.0	69.0	-	-
3/8"	6.07	13.04	27.0	58.0	42.0	37.5	20
#4	8.09	21.13	36.0	94.0	6.0	5	0
#8	0.90	22.03	4.0	98.0	2.0	2.5	0
PAN	0.45	22.48	2.0	100.0	0.0	-	-

Other Test Results

Test Name	Date	Result	Unit	Target	Specification %
Wash Loss (#200)	AVG	1.01%	%	0.745	0 1.49

